

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F 6/DFS/MS/School/2020/SZ/ 246

Dated: 14/9/2020

FIRE SAFETY CERTIFICATE

Certified that the Kendriya Vidyalaya, Vikas Puri, Hastal Village, Uttam Nagar, New Delhi-110059, comprised of ground floor plus three upper floors having total 65 rooms (including Class rooms, Offices, Sci Lab, Comp. room, Sports room, Examination room, Staff room & Store etc.) was issued FSC by this department vide letter no. F6/DFS/MS/School/2015/SZ/2196 dated 17.12.2015. The School building was re-inspected by the officer concerned of this department on 26.08.2020 in the presence of Sh. N.K. Verma (Maintenance In-charge) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Educational" w.e.t. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 14/9/2020 at New Delhi.

जायलिय कां कांहेकु

डकुमार
12/1/2020

(S.S.TULI)
Dy. CHIEF FIRE OFFICER
SOUTH ZONE

Copy to:-

1. The Principal,
Kendriya Vidyalaya, Vikas Puri, Hastal Village,
Uttam Nagar, New Delhi-110059.
2. The Dy. Commissioner K.V.S.,
Delhi Region, JNU Campus,
New Mehrauli Road, New Delhi-110067.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Hose reels are to be accessible at all time.
10. Corridor should be clear of obstruction at all time.

Received Copy
1-10/11/20/2020
Nehring